# **UPG-P9**





### **POWERED BY**









Three phase



water cooled



DIESEL



Battery Charging Alternator

## Ratings @ 0.8 PF

VOLTAGE	FREQENCY	PRIME RATING		PRIME RATING STAND-BY RATING		D-BY RATING
230/400 V	50 Hz	9.0 kva	7.2 kw	9.9 kva	7.9 kw	

These ratings are applicable for supplying continuous electrical power (at variable load). There is no annual hours limitation and this genset can supply 10% overload for  $1\ \text{hour}$  in  $12\ \text{hours}$ 

### Stand by

These ratings are applicable for supplying continuous electrical power(at variable load) in the case of emergency power supply. No overload is permitted on the ratings.

The alternator on this model is peak continuous rates (as defined in ISO 8528-5)

Some of the specifications are not standard on all Genset models.

Genset Standard Specification		
Model	UPG-P9	
Base frame	Heavy duty fabricated steel	
Circuit breaker	ABB 3 pole MCB (4 pole is optional)	
Engine speed	1500 RPM(50HZ)	
Fuel tank capacity	51 L-open & 58 L-closed	
Air inlet	Mounted air filter	
Induction system	Naturally Aspirated	
Combustion system	Indirect Injection	
Fuel system	Rotary type pump	
Fuel filter	Split element	
cooling system	Water-cooled	
Electric Equipment	12 v starter motor and 12 v DC alternator and 12 v shut off selenoid	

**Genset Model** UPG-P9 **Engine Model** Perkins 403 A-11G1 **Alternator Model TAL 040 B DSE 4520 Controller Model** 





Dimension				
Closed type(mm)		Open type(mm)		
Length	1560	Length	1450	
Width	760	Width	700	
Height	960	Height	900	
Weight(kg)	525	Weight(kg)	325	

Engine Data			
Model	Perkins 40	03A -11G1	
No of cylinder & arrangement	3 vertical in-line		
Compression ratio	23:1		
Aspiration	Naturally Aspirated		
Bore and stoke	77 x 81 mm		
Rotation	Anti-clockwise viewed on flywheel		
Governor type	Mechanical		
Radiator cooling air flow(m³/min)	0.44		
	50 Hz		
	Prime	Stand by	
Gross engine power kw(hp)	8.6 (11.5)	9.5 (12.7)	
at 50% Load(I/hr)	1.7	-	
at 75% Load(I/hr)	2.3	-	
at 100% Load(I/hr)	3.0	3.6	
Boost pressure ratio	4.9	4.9	
Total lubrication system capacity(L)	4.9	4.9	
Total Coolant capacity(L)	5.2	5.2	

Make	Leroy Somer	
Model	TAL 040 B	
Insulation class	Н	
No of bearing	1	
Total harmonic content	at no load<3.5%, on load<5%	
Winding pitch	2/3	
Ingress Protection	IP23	
Overspeed	2250 R.P.M	
AVR Model	R120	
Excitation system	SHUNT	
Voltage regulation(steady)	±1%	

All information in this document is substantially correct at the time of printing and may be altered subsequently.



#### **Enclosure**

- Full length extra wide doors on each side
  Radiator fill access plate
  Vertical hinged side door 180° opening rotation
  Back door option also available
  Control panel viewing window in a lockable access door
  Emergency stop push button (red) fixed externally for quick access
  Cooling fan and battery charging alternator fully guarded
  Fuel fill and battery can only be reached via lockable access doors

- Exhaust silencing system totally enclosed for operator safety

### HIGLY CORROSION RESISITANCE CONSTRUCTION

- · Carbon steel locks and hinges
- Body made from galvanized steel components (2.0mm) treated with polyester powder coating

#### TRANSPORTABILITY

· Tested and certified single point lifting facility

### SOUND PRESSURE LEVEL

- 75/80 dBA at 3 meters (standard)
- IP Rating IP54

Control Panel Data			
Make	Deep Sea		
Model	DSE 4520 MKII		



### **Controller key features**

The DSE 4520 is an Auto Start Control Module for single genset applications. It includes a backlit LCD display which clearly shows the status of the engine all the times. This module can either be programmed using the front panel or by using the DSE configuration suite PC

### Metering and Alarm indications:

- Generator frequency
- Underspeed, Overspeed
  Generator volts (L-L, L-N)
- · Generator current
- · Engine oil pressure
- Engine coolant temperature Fuel level (Warning or shutdown) Optional
- · Hours run counter
- Battery voltsFail to start/stop
- · Emergency stop
- Failed to reach loading voltage/frequency
   Charge fail
- Loss of magnetic pick-up signal Optional
   Low DC voltage
- · CAN diagnostics and CAN fail/error

#### FUEL SYSTEM

On Generating Sets up to 700 KVA, the baseframe design is incorporated with an integral fuel tank with a capacity of approx. 24 hours running at Full Load. The tank is supplied complete with fill cap breather, fuel feed and return lines to the Engine and drain plug.

Max allowable pressure	50 Hz
Кра	10
Exhaust gas flow m³/min	50 Hz
Prime	1.66
Standby	1.8
Exhaust gas temperature °C	50 Hz
Prime	368
Stand by	420

#### **AUTOMATIC VOLTAGE REGULATOR (AVR)**

The fully sealed Automatic Voltage Regulator maintains the Voltage Regulation at  $\pm 1\%$ . Nominal adjustment by means of a trim pot incorporated on the AVR.

#### MOTOR STARTING

An overload capacity equivalent to 300% of the Full Load impedance at zero Power Factor can be sustained for 10 seconds, when PMG option is fitted.

#### COUPLING

The Engine and Alternator are directly coupled by means of an SAE flange. The Engine flywheel is flexibly coupled to the Alternator rotor.

### ANTI-VIBRATION MOUNTING PADS

Anti-Vibration pads are affixed between the Engine / Alternator feet and the Baseframe thus ensuring complete vibration isolation of the rotating assembly.

### SAFETY GUARDS

The Fan & Fan Drive along with the Battery Charging Alternator are Safety Guard protected for personnel protection.

### **FACTORY TESTS**

The Generating set is load tested before dispatch All protective devices control functions and site load conditions are simulated. The generator and it's systems are checked before dispatch.

### **DOCUMENTATIONS**

Operation & Maintenance manual, Circuit wiring diagrams and Commissioning / Fault Finding accompanied with the Generator.

### **QUALITY STANDARDS**

Compliance with BS4999, BS5000, BS5514 IEC 60034, VDE0530, NEMA MG 1.22 and ISO 8528 standards

### WARRANTY

All of the Generating Sets are covered under a warranty policy for a period of 12 months. Warranty of the equipment is in line with manufacturers warranty terms & conditions.

All information in this document is substantially correct at the time of printing and may be altered subsequently.