# DATA SHEET SPECIFICATION

60 Hz

**UPG-P600** 



# **POWERED BY**



# Ratings @ 0.8 PF

VOLTAGE	FREQENCY	PRIME R	ATING	STAND	-BY RATING
230/380 v	60 Hz	625.0 kva	500.0 kw	687.0 kva	549.6 kw

### Prime

These ratings are applicable for supplying continuous electrical power (at variable load). There is no annual hours limitation and this genset can supply 10% overload for 1 hour in 12 hours

### Stand by

These ratings are applicable for supplying continuous electrical power(at variable load) in the case of emergency power supply. No overload is permitted on the ratings. The alternator on this model is peak continuous rates(as defined in ISO 8528-5)

Some of the specifications are not standard on all Genset models.

Model	UPG-P600	
Base frame	Heavy duty fabricated steel	
Circuit breaker	ABB 3 pole MCCB (4 pole is optional)	
Engine speed	1800 RPM(60HZ)	
	1485 - closed	
Fuel tank capacity(L)	734 - Open	
Air inlet	Mounted air filter	
Induction system	Parallel Turbocharged and air to air charge cooled	
Cycle	4 stroke	
Combustion system	Direct injection	
Fuel system	Fuel injection pump	
Fuel filter	Split element	
cooling system	Water-cooled	
Electric Equipment	24 v starter motor and 24 v DC alternator and ECM	

Genset Model Engine Model Alternator Model Controller Model

### UPG-P600

Perkins 2806A-E18TAG1A

TAL 0473 E

### odel





	Di	imension	
Closed	type(mm)	Open type	(mm)
Length	5700	Length	3800
Width	1900	Width	1600
Height	2360	Height	2300
Weight(kg)	5375	Weight(kg)	3700

	Engine Data		
Model	Perkins 2806A	A-E18TAG1A	
No of cylinder & arrangement	6 vertical	in-line	
Compression ratio	14.5:	1	
Bore and stroke(mm)	145 x 1	83	
Displacement / Cubic Capacity litres	18.1		
Rotation	Anti-clockwise, view	ed from flywheel	
Governor class	ISO 8528	8-5 G3	
Radiator cooling air flow(m³/sec)	11.7		
	60 Hz/1800 RPM		
	Prime	Stand by	
Gross engine power kw(hp)	568(762)	623(835)	
at 50% Load(I/hr)	61	_	
at 75% Load(I/hr)	90	-	
at 75% Load(I/hr) at 100% Load(I/hr)	90	- 134	
		- 134 62	

Alternator Data

Make	Leroy Somer
Model	TAL 0473 E
Insulation class	E
No of bearing	1
Total harmonic content	at no load <15% / <2% at linear load <5%
Winding pitch	2/3
Ingress Protection	IP23
Altitude	≤1000m
Overspeed	2250 R.P.M
AVR Model	R150
Excitation system	SHUNT
Voltage regulation(steady)	± 0.8%

AREP or PMG Excitation System Available as Optional

All information in this document is substantially correct at time of printing and may be altered subsequently.

# www.ultrapowergen.com

Copyright (C) 2024. Ultra Power Generators. Contact : +971505916054 All rights reserved.



### Enclosure

### SILENT FEATURES:

- Lockable external fuel filling point Internal /External fuel connection External oil drainage

- External coolant drainage Air inlet /outlet louvers Sound splitters at radiator side (only for 1000 KVA and above) (For 725-880 KVA vertical air discharge)
- Common earth connection
- Cooling fan and battery charging alternator fully guarded Engine, radiator, fuel fill and battery can only be reached via lockable access doors

#### HIGLY CORROSION RESISITANCE CONSTRUCTION

- Carbon steel locks and hinges
- Body made from galvanized steel components treated with polyester powder coating

# TRANSPORTABILITY

- Tested and certified single point lifting facility • Forklift legs available
- SOUND PRESSURE LEVEL
- 80 85 dBA at 3 meters (standard)

#### SECURITY AND SAFETY:

- Control panel viewing window in a lockable access door
- Emergency stop push button (red) fixed externally for quick access Cooling fan and battery charging alternator fully guarded Fuel fill and battery can only be reached via lockable access doors
- Exhaust silencing system totally enclosed for operator safety

Control Panel	Data	
Make	Deep Sea	
Model	DSE 7320 MKII	

#### **Controller key features**

The DSE DSE 6120 is an Auto Start Control Module for single genset applications. It includes a backlit LCD display which clearly shows the status of the engine all the times. This module can either be programmed using the front panel or by using the DSE configuration suite PC software.

#### Metering and Alarm indications:

- Generator frequency
  Underspeed, Overspeed
- Generator volts (L-L, L-N)
- Generator current
- Engine oil pressure
- Engine coolant temperature
- Hours run counter
  Battery volts
  Fail to start/stop
- Emergency stop
- Charge fail
  Low DC voltage

#### FUEL SYSTEM

On Generating Sets up to 700 KVA, the baseframe design is incorporated with an integral fuel tank with a capacity of approx. 8 hours running at Full Load. The tank is supplied complete with fill cap breather, fuel feed and return lines to the Engine and drain plug.

Silencer noise reduction level	60 Hz
dBA	14
Max allowable pressure	60 Hz
Кра	6.8
Exhaust gas flow m³/min	60 Hz
Prime	109
Prime Standby	109 118
Standby	118

#### AUTOMATIC VOLTAGE REGULATOR (AVR)

The fully sealed Automatic Voltage Regulator maintains the Voltage Regulation at  $\pm 1\%$ . Nominal adjustment by means of a trim pot incorporated on the AVR.

#### MOTOR STARTING

An overload capacity equivalent to 300% of the Full Load impedance at zero Power Factor can be sustained for 10 seconds, when PMG option is fitted.

#### COUPLING

The Engine and Alternator are directly coupled by means of an SAE flange. The Engine flywheel is flexibly coupled to the Alternator rotor.

#### ANTI-VIBRATION MOUNTING PADS

Anti-Vibration pads are affixed between the Engine / Alternator feet and the Baseframe thus ensuring complete vibration isolation of the rotating assembly.

#### SAFETY GUARDS

The Fan & Fan Drive along with the Battery Charging Alternator are Safety Guard protected for personnel protection.

#### FACTORY TESTS

The Generating set is load tested before dispatch All protective devices control functions and site load conditions are simulated. The generator and it's systems are checked before dispatch.

### DOCUMENTATIONS

Operation & Maintenance manual, Circuit wiring diagrams and Commissioning / Fault Finding accompanied with the Generator.

### **QUALITY STANDARDS**

Following standards: ISO 8528/1, ISO 3046/1, BS 5514/1.

## WARRANTY

All of the Generating Sets are covered under a warranty policy for a period of 12 months. Warranty of the equipment is in line with manufacturers warranty terms & conditions.

All information in this document is substantially correct at time of printing and may be altered subsequently.

# www.ultrapowergen.com

Copyright (C) 2024. Ultra Power Generators. All rights reserved.