# **UPG-P500**





# **POWERED BY**









Three phase



water cooled



DIESEL



Battery Charging Alternator

# Ratings @ 0.8 PF

VOLTAGE	FREQENCY	PRIME F	RATING	STANI	D-BY RATING
230/380 v	50 Hz	500.0 kva	400.0 kw	550.0 kva	440.0 kw

These ratings are applicable for supplying continuous electrical power (at variable load). There is no annual hours limitation and this genset can supply 10% overload for 1 hour in 12 hours

# Stand by

These ratings are applicable for supplying continuous electrical power(at variable load) in the case of emergency power supply. No overload is permitted on the ratings.

The alternator on this model is peak continuous rates (as defined in ISO 8528-5)

Some of the specifications are not standard on all Genset models.

Genset Standard Specification			
Model	UPG-P500		
Base frame	Heavy duty fabricated steel		
Circuit breaker	ABB 3 pole MCCB.(4 pole is optional)		
Engine speed	1500 RPM(50HZ)		
Fuel tenk conscitu	1230 L-Closed		
Fuel tank capacity	701 L- Open		
Air inlet	Mounted air filter		
Induction system	Turbo charged and air to air charge cooled		
Cycle	4 stroke		
Combustion system	Direct injection		
Fuel system	Fuel injection pump		
Fuel filter	Split element		
cooling system	Water-cooled		
Electric Equipment	24 v starter motor and 24 v DC alternator and ECM		

All information in this document is substantially correct at time of printing and may be altered subsequently.

Genset Model	UPG-P500
Engine Model	Perkins 2506A-E15TAG2
Alternator Model	TAL 0473 C
Controller Model	DSE 7320





	Di	imension	
Closed type(mm)		Open type(mm)	
Length	4950	Length	3800
Width	1600	Width	1200
Height	2210	Height	1800
Weight(kg)	4650	Weight(kg)	3430

Model	Devloine 2500A	FIFTA CO
Model	Perkins 2506A-	EI5TAG2
No of cylinder & arrangement	6 vertical in	ı-line
Compression ratio	18.2:1	
Aspiration	Turbocharged and a cooled	_
Bore and stroke(mm)	130 x 171	
Displacement / Cubic Capacity litres	15.2	
Rotation	Anti-clockwise, viewed on flywheel	
Governor class	ISO 8528-5 G3	
Radiator cooling air flow(m³/sec)	9.6	
	50 Hz/1500 RPM	
	Prime	Stand by
Gross engine power kw(hp)	451(605)	495(664)
at 50% Load(I/hr)	53.0	-
at 75% Load(I/hr)	76.0	- 1
at 100% Load(I/hr)	100.0	111.0
Total lubrication system capacity(L)	62 .0	62.0
Total Coolant capacity((I/hr))	58.0	58.0

ternator Data	
Make	Leroy Somer TAL / Equivalent
Model	TAL 0473 C
Insulation class	Н
No of bearing	1
Total harmonic content	at no load <2.5% / <2% at linear load <5% / <5%
Winding pitch	2/3
Ingress Protection	IP23
Altitude	≤1000m
Overspeed	2250 R.P.M
AVR Model	R150
Excitation system	SHUNT
Voltage regulation(steady)	± 0.8% / ± 1%
REP or PMG Excitation System A	vailable as Optional



### **Enclosure**

### **SILENT FEATURES:**

- Lockable external fuel filling point Internal /External fuel connection External oil drainage

- External coolant drainage
  Air inlet /outlet louvers
  Sound splitters at radiator side (only for 1000 KVA and above) (For 725-880 KVA vertical air discharge)
- Common earth connection

- powder coated galvanized canopy Cooling fan and battery charging alternator fully guarded Engine, radiator, fuel fill and battery can only be reached via lockable access doors

### HIGLY CORROSION RESISITANCE CONSTRUCTION

- Carbon steel locks and hinges
- Body made from galvanized steel components treated with polyester powder coating

### **TRANSPORTABILITY**

- Tested and certified single point lifting facility
- · Forklift legs available

### SOUND PRESSURE LEVEL

• 80 - 85 dBA at 3 meters (standard)

# **SECURITY AND SAFETY:**

- Control panel viewing window in a lockable access door

- Emergency stop push button (red) fixed externally for quick access Cooling fan and battery charging alternator fully guarded Fuel fill and battery can only be reached via lockable access doors
- Exhaust silencing system totally enclosed for operator safety

Control P	anel Data
Make	Deep Sea
Model	DSE 7320 MKII



## Controller key features

The DSE DSE 6120 is an Auto Start Control Module for single genset applications. It includes a backlit LCD display which clearly shows the status of the engine all the times. This module can either be programmed using the front panel or by using the DSE configuration suite PC software.

### Metering and Alarm indications:

- · Generator frequency · Underspeed, Overspeed
- · Generator volts (L-L, L-N)
- Generator current
- · Engine oil pressure
- · Engine coolant temperature
- Hours run counter
   Battery volts
   Fail to start/stop
- Emergency stop
- · Charge fail · Low DC voltage

# All information in this document is substantially correct at time of printing and may be altered subsequently.

### **FUEL SYSTEM**

On Generating Sets up to 700 KVA, the baseframe design is incorporated with an integral fuel tank with a capacity of approx. 8 hours running at Full Load. The tank is supplied complete with fill cap breather, fuel feed and return lines to the Engine and drain plug.

Silencer noise reduction level	50 Hz
dBA	15
Max allowable pressure	50 Hz
Кра	6.8
Exhaust gas flow m³/min	50 Hz
Prime	94
Prime Standby	94 98
Standby	98

### **AUTOMATIC VOLTAGE REGULATOR (AVR)**

The fully sealed Automatic Voltage Regulator maintains the Voltage Regulation at ±1%. Nominal adjustment by means of a trim pot incorporated on the AVR.

### MOTOR STARTING

An overload capacity equivalent to 300% of the Full Load impedance at zero Power Factor can be sustained for 10 seconds, when PMG option is fitted.

### COUPLING

The Engine and Alternator are directly coupled by means of an SAE flange. The Engine flywheel is flexibly coupled to the Alternator rotor.

### ANTI-VIBRATION MOUNTING PADS

Anti-Vibration pads are affixed between the Engine / Alternator feet and the Baseframe thus ensuring complete vibration isolation of the rotating assembly.

### SAFETY GUARDS

The Fan & Fan Drive along with the Battery Charging Alternator are Safety Guard protected for personnel protection.

### **FACTORY TESTS**

The Generating set is load tested before dispatch All protective devices control functions and site load conditions are simulated. The generator and it's systems are checked before dispatch.

### **DOCUMENTATIONS**

Operation & Maintenance manual, Circuit wiring diagrams and Commissioning / Fault Finding accompanied with the Generator.

# **QUALITY STANDARDS**

Following standards: ISO 8528/1, ISO 3046/1, BS 5514/1.

# WARRANTY

All of the Generating Sets are covered under a warranty policy for a period of 12 months. Warranty of the equipment is in line with manufacturers warranty terms & conditions.